

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20190611-E482927  
**Report Reference** E482927-20160325  
**Issue Date** 2019-JUNE-11

**Issued to:** SPINA GROUP SRL  
Via del Tecchione 36/B  
20098 San Giuliano Milanese, MI ITALY

**This is to certify that representative samples of** Cable Trays, Metal  
USC – Cable Trays: Perforated Channel cable tray type AR with bordered flange, Perforated Channel cable tray type PS simple flange and solid Channel cable tray type FC with bordered flange.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** Metal cable trays and metal cable tray systems have been investigated to determine their suitability for use as equipment grounding conductors in accordance with Sections 392.60(A) and 392.60(B) of ANSI/NFPA 70, "National Electrical Code."  
NEMA VE 1, "Metal Cable Tray Systems."

**Additional Information:** See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

